

April 16, 2020

Q&A RFP 2020 -06

Q. Interested in obtaining the plan sheets for the above mentioned project. I have downloaded the Specs off the website and was curious about plan sheets.

A. There is no plan sheet for a specific projects as of yet. There is more than one project site and may require different depths and widths of trenching. Using the typical examples of trenching and standards, price quotes per linear foot is requested. If a plan sheet is required at any site, it would be generated for that location. The contractor may offer to provide plan sheets as an option in the proposal.

Q. Is there any need for directional drilling (Utility Bore) in the contracted service?

A. The primary price agreement requested is for trenching. However if the contractor has the capacity to provide Directional Drilling, they may offer that pricing of Bore service as an option.

Q. What is the first trenching project that the Village will contract?

A. the Amizette area undergrounding of electricity along NM150 is of safety priority but the contract is also considered On Call. If there were an immediate need for services within the Village another project site may come first.