



SHEAR PLATE CONNECTOR SCHEDULE		
BEAM TO COLUMN	** DEPTH OF PLATE	* NO OF BOLTS
C9 & W8	6	2
C12 & W12,14	9	3
C15 & W16	12	4
W18	15	5
W21	18	6
W24-W36	21	7
*ALL BOLTS TO BE 3/4"Ø A325-N		
** PLATE 3/8"x4" DEPTH OF PLATE W/ 5/16" WELD ALL AROUND		





D4 DETAIL
NTS



A4 TYP WOOD BEAM BEARING


CMU LINTEL SCHEDULE UNLESS OTHERWISE DRAWN OR NOTED					
MAX SPAN	BLK SIZE	'H' MIN	TOP REINF	BOTT REINF	REMARKS
3'-0"	8"x8x16	16"		2 #5	16" BEARING EA END
4'-0"	8"x8x16	16"		2 #5	16" BEARING EA END
6'-0"	8"x8x16	24"	2 #5	2 #5	24" BEARING EA END
8'-0"	8"x8x16	24"	2 #5	2 #5	32" BEARING EA END
10'-0"	8"x8x16	24"	2 #5	2 #5	48" BEARING EA END
12'-0"	8"x8x16	24"	2 #5	2 #5	
* LINTEL WIDTH SHALL MATCH WALL TOP BARS SHALL HOOK 90 AT ENDS					

B4 TYP OPENING IN CMU WALL
REINFORCING ELEVATION




SECTION 'A'

LINTEL SCHEDULE	
SPAN	HEADER
UP TO 6'-0"	2 - 2x10
6'-0" TO 8'-0"	2 - 2x12
8'-0" TO 10'-0"	3 - 2x12




A5 TYP WOOD LINTEL


B5 TYP OPENING IN
PLYWOOD DECK



C5 TYP WOOD BEARING




D5 TYP CONTROL JOINT
AT BOND BEAM



TYPICAL DETAILS

SHEET TITLE:

PROJECT TITLE:
VTSV ADMINISTRATION BUILDING
VILLAGE OF TAOS SKI VALLEY, NM



REVISION	BY	APPVD.	DATE
No.			
DESIGNED:	RHW		
CHECKED:	RHW		
DRAFTER:	DJH		
DATE:	DDMMYY		
SCALE:	AS NOTED		

SHEET No.

S-003

OF: xx

HIGH DESERT
STRUCTURAL ENGINEERING

1911 FIFTH STREET SUITE 205
SANTA FE, NEW MEXICO 87505

THIS DRAWING IS THE PROPERTY OF HIGH DESERT STRUCTURAL ENGINEERING, L.L.C. AND IS NOT TO BE REPRODUCED, COPIED, OR USED FOR ANY OTHER PROJECT WITHOUT THE WRITTEN PERMISSION OF HIGH DESERT STRUCTURAL ENGINEERING, L.L.C.

505-780-8897