



GENERAL SHEET NOTES	SHEET KEYNOTE	SCHEDULES	LEGEND
<ol style="list-style-type: none"> CONTRACTOR SHALL VERIFY ALL HORIZONTAL AND VERTICAL DIMENSIONS PRIOR TO FABRICATION OF CONSTRUCTION ELEMENTS. CONTRACTOR SHALL PROVIDE TEMPORARY SHORING AS NECESSARY FOR ALL ITEMS UNTIL FINAL CONSTRUCTION ELEMENTS ARE IN PLACE. SOME SHEET KEYNOTES MAY NOT APPLY TO THIS SHEET. DIMENSIONS ARE TO THE FACE OF STUD UNLESS NOTED OTHERWISE. ALL STRUCTURAL STUD WALLS ARE 2x6 AT 16" ON CENTER UNLESS NOTED OTHERWISE. PRE-ENGINEERED, PRE-MANUFACTURED WOOD TRUSSES AT 24" O.C. U.N.O. CONTRACTOR SHALL SUBMIT SHOP DRAWINGS AND CALCULATIONS TO ARCHITECT (HIGH DESERT STRUCTURAL ENGINEERING, LLC) FOR REVIEW. CALCULATIONS SHALL BE SEALED AND SIGNED BY A REGISTERED NEW MEXICO PROFESSIONAL ENGINEER. SEE GENERAL NOTES FOR STATIC AND LATERAL LOAD REQUIREMENTS. 	<ol style="list-style-type: none"> EXISTING VIGAS AND T&G CEILING TO REMAIN EXISTING FLOOR/CEILING FRAMING TO REMAIN NEW FLOOR FRAMING TO MATCH EXISTING 1 3/4"x11 7/8" PLYWOOD WEB I-JOISTS @ 24" O.C. 1 3/4"x11 7/8" PLYWOOD WEB I-JOISTS @ 16" O.C. MC 12X31 3/4" APA RATED PLYWOOD SUBFLOOR COMPOSITE CONCRETE METAL DECK. 1" TYPE C 24 GA. GALV. METAL DECK SMIN. = 0.098 IN3 IMIN. = 0.057 IN4. PROVIDE 3" CONCRETE TOPPING W/6 X 6- W1.4 X W1.4 W.W.F. FLAT SHEETS CHAIRED OVER METAL DECK. PROVIDE CONTROL JOINTS AT 20'-0" O.C. MAX. EACH DIRECTION. NEW BEAM TO SUPPORT EXISTING STRUCTURE COLUMN LOCATION ELEVATOR SUMP PIT. COORDINATE SIZE WITH ELEVATOR MANUFACTURER EPOXY DOWEL AT NEW FOUNDATION AND STEM WALL TO EXISTING USING #4 CONTINUOUS REBAR, MIN. 12" EMBED. NEW FOOTING AT EXISTING FOOTING COLUMN LOCATION 		<ul style="list-style-type: none"> NEW SUPPORT COLUMN LINTEL PER SCHEDULE UNLESS NOTED OTHERWISE PRE-MANUFACTURED WOOD ROOF TRUSS @ 24" O.C. U.N.O. EXISTING SUPPORT COLUMN TO REMAIN EXISTING BEAM TO REMAIN EXISTING WALL TO REMAIN NEW WALL OR INFILL WALL <p>5/8" CDX PLYWOOD. ATTACH WITH 8d NAILS AT 6" O.C. ALONG EDGES AND 12" O.C. ALONG INTERMEDIATE SUPPORTS. PROVIDE PLY CLIPS AT ALL UNSUPPORTED EDGES.</p> <p>3/4" T&G PLYWOOD SUBFLOOR. ATTACH WITH 8d NAILS AT 6" O.C. ALONG EDGES AND 12" O.C. ALONG INTERMEDIATE SUPPORTS.</p> <p>1" TYPE C 24 GA. GALV. METAL DECK SMIN = 0.098 IN3 IMIN = 0.057 IN4. PROVIDE 3" CONCRETE TOPPING W/6 X 6- W1.4 X W1.4 W.W.F. FLAT SHEETS CHAIRED OVER METAL DECK. PROVIDE CONTROL JOINTS AT 20'-0" O.C. MAX. EACH DIRECTION.</p>

